ATTACHMENT A

GREER COMMISSION OF PUB

INDUSTRIAL WASTEWATER DISCHA

PARAMETER	DAILY MAXIMUM CONCENTRATION (MG/L)	
ARSENIC	<u>0.339</u>	0.014
CADMIUM	<u>0.0045</u>	0.015
CHROMIUM (+6)	<u>0.75</u>	0.7
CHROMIUM (T)	<u>2.77</u>	1
COPPER	<u>0.282</u>	0.06
CYANIDE	0.09	0.2
LEAD	<u>0.03</u>	0.003
MERCURY	<u>0.0015</u>	0.0003
NICKEL	<u>0.2715</u>	0.6
SELENIUM	<u>0.018</u>	0.045
SILVER	<u>0.003</u>	0.36
ZINC	<u>0.8595</u>	0.6
PHENOL	<u>3</u>	10
BOD	300	
COD	1200	
TSS	300	
TOTAL KJELDAHL		
NITROGEN	30	

These industrial wastewater discharge limitations were ador. Greer Commission of Public Works Board of Commissioners and shall be effective on _____.

LIC WORKS

RGE LIMITATIONS

MONTHLY AVERAGE CONCENTRATION (MG/L)

<u>0.226</u> <u>0.003</u> 0.5	0.009 0.01
1.71	0.7
0.188	0.04
0.06	0.13
<u>0.02</u>	0.002
<u>0.001</u>	0.0003
<u>0.181</u>	0.4
<u>0.012</u>	0.03
<u>0.002</u>	0.24
<u>0.573</u>	0.4
<u>2</u>	7
200	
800	
200	
20	

oted by the

on _____